

## SAFETY BULLETIN FOR THE CHEM-TECH XP PUMP SYSTEM

**WARNING** to users of the **CHEM-TECH XP PUMP SYSTEM** for water treatment – please **STOP USING the CHEM-TECH XP PUMP SYSTEM** and contact your dealer at the number provided in the cover letter to this Safety Bulletin to immediately schedule an appointment for a replacement part free of charge.

In rare circumstances, a timer in the pump could cause an unintended imbalance in the pH of treated water which could lead to irritation or burning of the skin or throat (for drinking water).



This **WARNING** applies to the models identified in the chart below that were sold between 2009-2015 (Date Code 01/09-12/15). This issue is rare, however, in an abundance of caution, please **STOP USING the CHEM-TECH XP PUMP SYSTEM** and contact your dealer to immediately schedule an appointment for a replacement part free of charge.



**Date Code**

**Model Number**

### MODEL NUMBERS

XP015L5HX	XP030L1HX	XP015L1HX	XP030L2HX	XP050L3LX	XP004L54X
XP030L4HX-CA014	XP030L4HX-CA015	XP009L4LXR40	XP015L2HX055	XP007L2HXGE1	XP004L7H1
XP009L2HX	XP015L2HX	XP009L1LX	XP004L5HX	XP004L1LX	XP004L743
XP030L5HX	XP004L4HX	XP023L3HX	XP004L1HX	XP007L2HX	XP004L7HX
XP050L2LX	XP004L5FX	XP23L5HX	XP007L2LX	XP050L5LX	XP023L3LX
XP030L3HX	XP007L1HX	XP030L7HX	XP030L2LX	XP009L4LX	XP030L24X
XP007L5HX	XP030L4HX	XP023L1HX	XP015L4HX	XP007L733	XP007L2LT
XP009L2LX	XP007L24X	XP009L1HX	XP015L7HX	XP050L33X	XP048L3LX
XP004L1NX	XP015L1LX	XP004L4LX	XP007L1LX	XP004L5HT	XP004L54X